

Village Board Meeting

April 2024

Streets

- Started leaf and brush pick up.
- High St bridge is close to being completed.
- “No parking, here to corner” signs have been purchased and I am waiting for confirmation on footage from intersection to place them.
- The village barn gate in the rear is closed indefinitely and just the front one will be used. It has been serviced and is operational.

Water

- We had to dig up our curb valve at 124 High St to prove we had sufficient pressure at that point.
- The plant is running well.
- Our telemetry for the storage tank failed. Had to have Aqualogics come out for a service call. Turned out to be a bad transmitter.
- Completed approximately 16 more lead service line inspections last week alone. We are currently at 31 completed.
- New locks have been placed on both reservoir gates and keys made up for them.

Sewer

- The plant is running well.
- Mark has submitted his application for his wastewater ABC exam. He has been approved and will schedule his test date within the week.